

Floor gully, Purus MiniMax 50

Holder/Issued to

Purus AB

Södra Dragongatan 15, SE-271 39 Ystad, Sweden
VAT-number: 559007-0032
Telephone: +4610-41 44 900, fax: +4610-41 44 996
Mail address: info@purus.se Web site: www.purus.se

Product description

Floor gully Purus MiniMax 50 consists of gully body, water trap, clamping ring and grating. All parts are made of plastic (PP polypropene). The grating has an outer diameter of 130 mm, loading class K 3. MiniMax 50 has side outlet DN 50. Purus MiniMax 50 may be equipped with extension ring FHP. The extension ring ought to have a Type Approval.

Intended use

Purus MiniMax 50 is intended for domestic waste water and for installation in concrete or timber floor constructions with plastic or clinker surface.
In spaces without requirements for watertight layer the gully may be mounted in concrete floors or concrete floors with an epoxy layer. Mounting in epoxy requires an insert to the gully.

Trade name

Purus MiniMax 50 – Ø130 mm, RSK number (Product code) 7113764

Approval

The product has been found to meet the requirements in the following sections of Boverket Building Regulations (BBR):

Waste water installations	6:641,	1 st and last sentence in 2 nd paragraph
Design	6:644,	1 st sentence and 2 nd paragraph
Fixtures, fittings and equipment	8:32	

Associated documents

Installation instruction Purus floor gullies 130 MiniMax, dated 2012-01-16.
Installation instruction for Water trap NOOD, version 04.2009.
Operating and maintenance instructions Purus floor gullies - general, version 2011: 1.

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 351. Inspection body: DTI, Danish Technological Institute.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents.

Certificate no. 0117/06 | 2018-03-29

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sverige
Tel: +46 10-516 50 00
certifiering@ri.se | www.ri.se

2017-08-18



7P06445

(PX20493)



Manufacturing place

Production control includes the following place: Purus AB, Södra Dragongatan 15, SE-271 39 Ystad, Sweden

Marking

The product is to be marked at the factory. The marking consists of a text on every product/packing/documentation supplied and includes:

Product label on the product is marked:

Holder of certificate

Manufacturing place /Factory code

P-mark

Certification body

Product type designation

Certificate number

Consecutive manufacture no.

Inspection body

Purus

Purus



RISE Certifiering

Purus MiniMax 50- Ø130 mm

0117/06

number

351, DTI

Product is marked:

Holder

Consecutive production month/year

RSK number CLAMPING RING (plastic)

RSK number NOOD WATER TRAP (plastic)

RSK number PLASTIC GRATE, ART DECO (plastic)

Purus

month/year

714 13 16

711 37 65

713 84 47

Basis for judgement/approval

Report 732649-1 and report 757089 from DTI.

Comments

The gully is approved according to standard SS-EN 1253-1:2015. Installation instructions shall be delivered in each package. The function of the partially mechanical trap has been deemed to correspond to a trap depth of 50 mm. The removable water trap needs to be cleaned regularly.

This approval supersedes the previous approval with the same number dated 2012-04-03.

Validity

Valid through 2023-03-28

Johan Åkesson

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.