

## Floor gully, Purus Shower gully

Holder/Issued to

### Purus AB

Address: Södra Dragongatan 15, SE-271 39 Ystad, Sweden

VAT-number: 559007-0032

Telephone: +4610-41 44 900, fax: +4610-41 44 996

Mail address: [info@purus.se](mailto:info@purus.se) Web site: [www.purus.se](http://www.purus.se)

### Product description

Purus Shower gully consists of gully body, water trap, clamping ring and grating. The gully body is made of ABS plastic; all other parts are made of PP plastic (polypropylene). The gully has a vertical DN 50 outlet. The grating "P 150 GRATE, PLASTIC" has an outer diameter of 150 mm and belongs to loading class K 3 (300 kg). Purus Shower gully can be equipped with an extension ring FHP. The extension ring ought to have a Type Approval. Flow capacity is 1.7 l/s via the outlet of the gully.

### Intended use

Floor gully intended for domestic waste water and for installation in concrete or timber floor constructions with plastic or clinker surface.

In spaces without requirements for watertight layer the gully may be mounted in concrete floors or concrete floors with an epoxy layer. Mounting in epoxy requires an insert to the gully.

### Trade name

Purus Duschbrunn (Purus Shower gully), RSK no. 7113527

### Approval

The product satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Waste water installations	6:641, 1 <sup>st</sup> and last sentence in 2 <sup>nd</sup> paragraph
Design	6:644, 1 <sup>st</sup> sentence and 2 <sup>nd</sup> paragraph
Fixtures, fittings and equipment	8:32

### Associated documents

Installation instruction Purus floor gullies 150 RAN, dated 2011-10-25.

Operating and maintenance instructions, Purus floor gullies - general, version 2011: 1.

### Control

The factory production control (FPC) is monitored by an independent inspection body.

Control agreement: 351. Inspection body: DTI, Danskt Teknologiskt Institut.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this approval is based.

Type approval 4713/90 | 2018-03-29

RISE Research Institutes of Sweden AB | Certification  
Box 857, SE-501 15 Borås, Sweden  
Phone: +46 10-516 50 00  
[certifiering@ri.se](mailto:certifiering@ri.se) | [www.ri.se](http://www.ri.se)

2018-03-16-20



7P06464

(PX20499)



Accred. no. 1002  
Certification of  
Products  
ISO/IEC 17065

## Manufacturing place

Production control includes the following place:  
Purus AB, Södra Dragongatan 15, SE-271 39 Ystad, Sweden

## Marking

The product is to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

### Packing is marked:

Holder	Purus
Manufacturing place-/Factory code	Purus
Product type designation	Duschbrunn (Shower gully) – Ø150 mm
Consecutive manufacture no.	number
Type approval number	4713/90
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification body	RISE Certifiering
Inspection body	351, DTI

### Product is marked:

Holder	Purus
Consecutive production month/year	month/year
RSK number CLAMPING RING 150 (plastic)	714 13 15
RSK number shower gully (water trap, plastic)	711 35 32
RSK number P 150 GRATE, PLASTIC	713 84 16

## Basis for judgement/approval

Report 732649-1 from DTI, Danish Technological Institute. Report P200524 and E30097C from SP Technical Research Institute of Sweden. Report 757089 from DTI.

## Comments

Purus shower gully is approved according to standard SS-EN 1253-1:2015. Installation instructions shall be delivered in each package. The removable water trap needs to be cleaned regularly

This approval supersedes the previous approval with the same number dated 2012-04-03.

## Validity

Valid through 2023-03-28.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Johan Åkesson

Stefan Coric

*This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.*