

## Floor gully, Purus Balder and Purus Sigyn

Holder/Issued to

## Purus AB

Södra Dragongatan 15, SE-271 39 Ystad, Sweden

VAT-number: 559007-0032

Telephone: +4610-41 44 900, fax: +4610-41 44 996

Mail address: [info@purus.se](mailto:info@purus.se) Web site: [www.purus.se](http://www.purus.se)

## Product description

Floor gullies Purus Balder and Purus Sigyn consist of gully body made of stainless steel with outlet DN 75. Purus Balder has a vertical outlet and Purus Sigyn has a side outlet. Each gully is equipped with a clamping ring, grating and water trap. The grating is made of plastic or stainless steel, with outer diameter 150 mm and belongs to loading class K 3 (300 kg). The water trap is made of plastic; model TYR or stainless steel; model RAN and NOOD WATER TRAP, STAINLESS STEEL. See information at Trade name for information about materials and flow capacity via outlet. Balder and Sigyn can be equipped with extension ring FHP, FHR or FHP/FLEX. The extension rings ought to have a Type Approval.

## Intended use

Purus Balder and Purus Sigyn are floor gullies intended for domestic waste water and for installation in concrete or timber floor constructions with plastic or clinker surface.

In spaces without requirements for watertight layer the gully may be mounted in concrete floors or concrete floors with an epoxy layer. Mounting in epoxy requires an insert to the gully.

## Trade name

<u>Model:</u>	<u>RSK no.:</u>	<u>Flow capacity:</u>
Purus Balder 75 R NOOD - Ø150 mm	7152479	
Purus Balder 75 R- Ø150 mm	7118081	2,1 l/s
Purus Balder 75 P- Ø150 mm	7118070	1,9 l/s
Purus Sigyn 75 R NOOD- Ø150 mm	7152480	
Purus Sigyn 75 R- Ø150 mm	7118085	1,0 l/s
Purus Sigyn 75 P - Ø150 mm	7118071	1,2 l/s

R= all parts are made of stainless steel.

P= gully body is made of stainless steel, water trap and granting are made of plastic (PP polypropene).

## Approval

The product satisfies the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Waste water installations	6:641, 1 <sup>st</sup> and last sentence in 2 <sup>nd</sup> paragraph
Design	6:644, 1 <sup>st</sup> sentence and 2 <sup>nd</sup> paragraph
Fixtures, fittings and equipment	8:32

Type approval 5314/91 | 2018-03-29

RISE Research Institutes of Sweden AB | Certification  
Box 857, SE-501 15 Borås, Sweden  
Phone: +46 10-516 50 00  
[certifiering@ri.se](mailto:certifiering@ri.se) | [www.ri.se](http://www.ri.se)

2018-01-16-20



7P06450

(PX20503)



### Associated documents

Installation instruction Purus floor gullies 150 RAN, dated 2011-10-25.  
Installation instruction for Water trap NOOD, version 04.2009.  
Operating and maintenance instructions Purus floor gullies - general, version 2011: 1.

### Control

The factory production control (FPC) is monitored by an independent inspection body.  
Control agreement: 351 Inspection body: DTI, Danish Technological Institute.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this approval is based.

### Manufacturing place

Production control includes the following place: Purus AB, Södra Dragongatan 15, SE-271 39 Ystad, Sweden

### Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

#### Packing is marked:

Holder	Purus
Manufacturing place-/Factory code	Purus
Product type designation	<i>according to trade name</i>
Consecutive manufacture no.	<i>number</i>
Type approval number	5314/91
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification body	RISE Certification
Inspection body	351, DTI

#### Product is marked:

Holder	Purus
Consecutive production month/year	<i>month/year</i>
RSK number CLAMPING RING 150 (in polypropene plastic)	714 13 15
RSK number NOOD WATER TRAP, STAINLESS STEEL	713 84 33
RSK number STEEL RAN (water trap in stainless steel)	711 80 84
RSK number TYR (water trap in plastic)	711 80 69
RSK number SR 150 GRATE, STAINLESS STEEL	713 83 32
RSK number P 150 GRATE, PLASTIC	713 84 16

### Basis for judgement/approval

Test report no. VTT-S-00918-17 from VTT Expert Services LTD. Report 757089 from DTI

### Comments

Purus Balder and Purus Sigyn are approved according to standard SS-EN 1253-1:2015. Installation instructions shall be delivered in each package. The removable water trap needs to be cleaned regularly.

This approval supersedes the previous approval with the same number dated 2012-02-17.

### Validity

Valid through 2023-03-28.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Johan Åkesson

Stefan Coric

*This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.*